NOTES:

- 1. FOR GRAVITY APPLICATIONS ONLY.
- 2. ALL PROCEPTOR UNITS ARE MANUFACTURED WITH FIBERGLASS REINFORCED PLASTICS.

PHYSICAL CHARACTERISTICS AND THICKNESS: POLYESTER RESIN AND E GLASS

- MINIMUM THICKNESS 1/4" WALL AND 3/8" TOP AND BOTTOM BOWLS.
- 3. ALL PROCEPTOR UNITS ARE TO BE INSTALLED IN ACCORDANCE WITH THE MANUFACTURERS INSTALLATION INSTRUCTION. STANDARD PIPING IS SCH. 40 PVC.

- STANDARD PIPING IS SCH. 40 PVC.
 GMC/OMC 500 3000 UNITS COME STANDARD WITH 4" INLET AND OUTLET (OTHER PIPE SIZE OPTIONS AVAILABLE ON REQUEST).
 EXTENSION COLLAR TO BE ORDERED TO MEET FINISHED GRADE, CUT ON SITE FOR FINAL ADJUSTMENT AND CAULKED WITH SIKAFLEX BY CONTRACTOR FOR WATERTIGHT SEAL.
 COVERS AVAILABLE FOR H20 TRAFFIC LOADING, PEDESTRIAN

- COVERS AVAILABLE FOR RZU TRAFFIC LOADING, FEDESTRIAIN
 LOADING OR ABOVE GROUND INSTALLATION.
 CONSULT GREEN TURTLE FOR OTHER SIZES.
 30 YEAR WARRANTY AGAINST LEAKS, AND STRUCTURAL FAILURE. 10.U.S. PATENT #5,746,912; CDN PATENT #2,195,822

US PAT. # 5746912 $\textit{Proceptor}^{\circledR}$

MANUFACTURER:

STEEL


LUGS


ZURN GREEN TURTLE


PROCEPTOR MODEL NUMBER: LIQUID CAPACITY (WORKING VOLUME): RATED FLOW: GMC 500-P UPC 500 US GAL. 6 FT 1133 PSF


STD. MAX BURIAL DEPTH TO TOP OF TANK: MAX VERTICAL LOAD: MONTH/YEAR OF MANUFACTURE:

DETAIL "A"









SCALE 1:35

FOR UPC/IAPMO INSTALLATIONS

FOR UPC/IAPMO INSTALLATIONS APPROVED UNDER PS 80-2008 MEETS ASTM C-581

GI 4"	LE: PROCEPTOR SEPARATOR MC 500-P UPC GALLON INTERCEPTOR INLET & OUTLET		DATE	DRAWN		Proceptor*
24	"TRIPLE ACCESSWAY	3				
PR	OJECT: WO:	4				
- ' ' '	.03201. WO.	5				
AVAILABLE OPTIONS (CHECKED IF REQUESTED)		6 7				
	OIL/GREASE SENSOR ALARM	8			İ	
	SUCTION PIPE FOR INDOOR INSTALLATION	9			1	
$\overline{}$	ABOVE GROUND CONFIGURATION	10			SIZE	DWG. NO. REV.
	DOUBLE WALL CONSTRUCTION	DRA	DRAWN BY: L. SIMKINS			GMC 500-P UPC 0
	OIL DRAW OFF PIPE TO CONNECT TO EXTERNAL OIL HOLDING TANK(FOR OIL ONLY)	\vdash	E DRAWN: 2018/			LE:1:35 DO NOT SCALE DRAWING SHEET 1 OF 1